



t: 1.705.719.1100  
f: 1.705.719.1109  
14 Cedar Pointe Drive  
Barrie, Ontario  
L4N 5R7  
[www.exp.com](http://www.exp.com)

## Grain Size Distribution Report HL-6 Coarse Aggregate


Project No.: BAR-00144411-B0  
Project Name: Lab Services  
Client: Strada Aggregates  
Sample No: N/A

Material: HL6 Clearstone  
Source: N/G  
Date Sampled: February 21, 2017  
Dated Tested: February 22, 2017

### TOTAL SAMPLE PERCENTAGES

Sieve Size	Percent Retained	Percent Passing	Specifications	Pass/Fail
26.5 mm	0.0	100	100.0	Pass
19 mm	2.1	98	90-100	Pass
16 mm	14.4	86	65-90	Pass
9.5 mm	61.1	39	20-55	Pass
4.75mm	94.2	6	0-10	Pass

### GRAIN SIZE DISTRIBUTION



#### DISTRIBUTION:

Strada Aggregates

Scott Fraser, C.E.T.

Leigh Knegt, P. Eng.